



Ref. Certif. No.

SG PSB-LE-04527

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

| | |
|---|--|
| Product | Electronic controlgear for LED modules Electronic converter of LED |
| Name and address of the applicant | Vossloh-Schwabe Deutschland GmbH Stuttgarter Straße 61/1 73614 Schorndorf GERMANY |
| Name and address of the manufacturer | Vossloh-Schwabe Deutschland GmbH Stuttgarter Straße 61/1, 73614 Schorndorf, GERMANY |
| |  |
| |  |
| Ratings and principal characteristics | Rated voltage: 220-240V~ Rated frequency: 50/60Hz Rated output: See model list Type of output: Constant current type tc: 80°C ta: -20...50°C Method of installation: Built-in use Protection against electric shock: Non-SELV |
| Model/type Ref. | ECXe 350.618, ECXe 500.620, ECXe 350.619, ECXe 500.621, ECXe 700.622 |
| A sample of the product was tested and found to be in conformity with | IEC 61347-1:2015 IEC 61347-1:2015/AMD1:2017 IEC 61347-2-13:2014 IEC 61347-2-13:2014/AMD1:2016 |
| as shown in the Test Report Ref. No. which forms part of this certificate | 083-2205435-000 |

Page 1 of 2

This CB Test Certificate is issued by the National Certification Body

CBS 049606 0022 Rev. 00

Date, 2022-10-28

(Yin Ji)

TÜV SÜD PSB Pte Ltd 15 International Business Park TÜV SÜD @ IBP Singapore 609937



PSB Singapore



Ref. Certif. No.

SG PSB-LE-04527

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Trademark / Brand (Image)



Model list:

| Model | P _{rated} (W) | Output Voltage (Vd.c.) | U _{out} (Vd.c.) | I _{rated} (A) |
|--------------|---------------------------|---------------------------|-----------------------------|------------------------|
| ECXe 700.622 | Max.91 | 40-130 | Max. 250 | Max.0.70 |
| ECXe 500.621 | Max.90 | 90-180 | Max. 250 | Max.0.5 |
| ECXe 350.619 | Max.84 | 120-240 | Max. 275 | Max.0.35 |
| ECXe 500.620 | Max.65 | 40-130 | Max. 250 | Max.0.5 |
| ECXe 350.618 | Max.45.5 | 40-130 | Max. 250 | Max.0.35 |

Page 2 of 2

This CB Test Certificate is issued by the National Certification Body

CBS 049606 0022 Rev. 00

Date, 2022-10-28

(Yin Ji)

TÜV SÜD PSB Pte Ltd 15 International Business Park TÜV SÜD @ IBP Singapore 609937



PSB Singapore