




Ref. Certif. No.

SG PSB-LE-04957

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Electronic controlgear for LED modules Electronic Converter for LED
Name and address of the applicant	Vossloh-Schwabe Deutschland GmbH Stuttgarter Straße 61/1 73614 Schorndorf GERMANY
Name and address of the manufacturer	Vossloh-Schwabe Deutschland GmbH Stuttgarter Straße 61/1, 73614 Schorndorf, GERMANY
Name and address of the factory	
Ratings and principal characteristics	details please see page 2
Model/type Ref.	EDXe 1100/24.041 Ref.-No. 186433; EDXe 1150/24.042 Ref.-No. 186434
Additional information (if necessary)	Certificate SG PSB-LE-02163M1 issued 2022-03-02 is replaced by this version due to technical changes.
A sample of the product was tested and found to be in conformity with	IEC 61347-1:2015 IEC 61347-1:2015/AMD1:2017 IEC 61347-2-13:2014 IEC 61347-2-13:2014/AMD1:2016
as shown in the Test Report Ref. No. which forms part of this certificate	083-2302013-000

Page 1 of 2

This CB Test Certificate is issued by the National Certification Body

CBS 049606 0008 Rev. 02

Date, 2023-05-08

(Yin Ji)

TÜV SÜD PSB Pte Ltd 15 International Business Park TÜV SÜD @ IBP Singapore 609937



PSB Singapore

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Trademark / Brand (Image)



Ratings and principal characteristics

Rated voltage:	220-240V~
Rated frequency:	50/60Hz
Rated input current:	
EDXe 1100/24.041 Ref.-No. 186433:	0,54-0,48A
EDXe 1150/24.042 Ref.-No. 186434:	0,80-0,72A
Rated output voltage:	24VDC
Rated output current:	
EDXe 1100/24.041 Ref.-No. 186433:	4,2A
EDXe 1150/24.042 Ref.-No. 186434:	6,25A
Rated output power:	
EDXe 1100/24.041 Ref.-No. 186433:	100W
EDXe 1150/24.042 Ref.-No. 186434:	150W
Protection Class:	I
Degree of protection:	IP67
ta:	-15-45°C
tc:	80°C
Temperature declared:	110°C
Install Classification:	independent
Protection against electric shock:	SELV
Type of output:	Constant output voltage

Page 2 of 2

This CB Test Certificate is issued by the National Certification Body

CBS 049606 0008 Rev. 02

Date, 2023-05-08



(Yin Ji)