



Ref. Certif. No.

SG PSB-LE-05675

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

| | |
|---|--|
| Product | Electronic controlgear for LED modules Electronic Converter for LED |
| Name and address of the applicant | Vossloh-Schwabe Deutschland GmbH Stuttgarter Straße 61/1 73614 Schorndorf GERMANY |
| Name and address of the manufacturer | Vossloh-Schwabe Deutschland GmbH Stuttgarter Straße 61/1, 73614 Schorndorf, GERMANY |
| Name and address of the factory | [REDACTED] |
| Ratings and principal characteristics | Rated voltage: 220-240V~ Rated frequency: 50/60Hz Rated input current: Refer to model list Rated output: Refer to model list Type of output: Constant current type Protection against electric shock: SELV tc: Refer to model list Method of installation: Built-in with double & reinforced insulation |
| Model/type Ref. | ECXe 700.671, ECXe 1050.673, ECXe 1400.672 |
| A sample of the product was tested and found to be in conformity with | IEC 61347-1:2015 IEC 61347-1:2015/AMD1:2017 IEC 61347-2-13:2014 IEC 61347-2-13:2014/AMD1:2016 |
| as shown in the Test Report Ref. No. which forms part of this certificate | 087-2303154-000 |

Page 1 of 2

This CB Test Certificate is issued by the National Certification Body

CBS 049606 0030 Rev. 00

Date, 2024-03-25

(Yin Ji)

TÜV SÜD PSB Pte Ltd 15 International Business Park TÜV SÜD @ IBP Singapore 609937



PSB Singapore



Ref. Certif. No.

SG PSB-LE-05675

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Trademark / Brand (Image)



Model list:

| Model | Supply current (A) | P _{rated} (W) | I _{rated} (A) | Output voltage (V) | U _{out} (V) | tc(°C) |
|---------------|--------------------|------------------------|------------------------|--------------------|----------------------|--------|
| ECXe 700.671 | 0,25 | Max.40 | 0,35-0,7 | 19-57 | 60 | 80 |
| ECXe 1050.673 | 0,36 | Max.60 | 0,7-1,05 | 19-57 | 60 | 80 |
| ECXe 1400.672 | 0,45 | Max.75 | 0,7-1,4 | 19-57 | 60 | 80 |

Page 2 of 2

This CB Test Certificate is issued by the National Certification Body

CBS 049606 0030 Rev. 00

Date, 2024-03-25

(Yin Ji)

TÜV SÜD PSB Pte Ltd 15 International Business Park TÜV SÜD @ IBP Singapore 609937



PSB Singapore