

DE 2-038934

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

Ratings and principal characteristics

Trademark (if any)

Customer's Testing Facility (CTF) Stage used Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

LED driver

Vossloh-Schwabe Deutschland GmbH Stuttgarter Str. 61/1

73614 Schorndorf, Deutschland

Vossloh-Schwabe Deutschland GmbH Stuttgarter Str. 61/1

73614 Schorndorf, Deutschland

See additional page(s)

AC 220-240V,50/60Hz; built-in type; thermally protection mark: 120; Max. output: 1) 26W, 2) 40W, 3) 60W, 4) 80W, 5) 120W;

6) 165W; 7) 200W

1)2)3): ta: -40°C~55°C; tc: 85°C; 4) : ta: -40°C~55°C; tc: 90°C; 5)6)7): ta: -40°C~50°C; tc: 90°C. VS LIGHTING SOLUTIONS

N/A

1) ECXd 1050.639 2) ECXd 1050.640 3) ECXd 1050.659

4) ECXd 1050.641 5) ECXd 1050.642 6) ECXd 1050.660

7) ECXd 1050.661

For model differences, refer to the test report.

IEC 61347-2-13:2014+A1 IEC 61347-1:2015+A1

CN23075D 001

This CB Test Certificate is issued by the National Certification Body



2023-06-06

TÜV Rheinland LGA Products GmbH Tillystr. 2, 90431 Nürnberg, Germany Phone + 49 221 806-1371 Fax + 49 221 806-3935

Mail: cert-validity@de.tuv.com

Web : www.tuv.com

Signature: Eileen Feng

Z. Van Us

Date:



DE 2-038934

Eileen Feng

Page 2 of 2 Additional information (if necessary) Report Ref. No.: CN23075D 001 Z. Warn Tys

Date:

2023-06-06

Signature: