CERTIFICATE

Issued to:
Applicant:
Vossloh-Schwabe Deutschland GmbH
Stuttgarter Str. 61/1
73614 Schorndorf, Germany

Licensee:

Vossloh-Schwabe Deutschland GmbH Stuttgarter Str. 61/1 73614 Schorndorf, Germany

Product : LED driver

Trade name(s) : VS LIGHTING SOLUTIONS

Type(s)/model(s) : ECXd 150.604, ECXd 250.597, ECXd 350.605 and ECXd 700.598

The product and any acceptable variation thereto as specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of

- a type test according to EN 61347-2-13:2014, EN 61347-2-13:2014/A1:2017, EN 61347-1:2015, EN 61347-1:2015/A1:2021 and EN IEC 62384:2020
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 6061104

DEKRA hereby grants the right to use the ENEC certification mark

The ENEC certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the ENEC certification agreement.

This certificate is issued on 1 August 2023 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 35-129884

DEKRA Certification B.V.

B.T.M. Holtus

Managing Director


M. Triulzi Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE DUTCH ACCREDITATION COUNCIL











SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

Product : LED driver

Trade name(s) : VS LIGHTING SOLUTIONS

Type(s)/model(s) : ECXd 150.604, ECXd 250.597, ECXd 350.605 and

ECXd 700.598

Rated voltage : 220-240 V
Rated frequency : 50/60 Hz
Ambient temperature (ta) : -15-45°C
Class of insulation : Class II

Additional information : independent type, SELV, constant current output,

non-inherently short circuit proof;

Degree of protection : IP20
Max. case temperature (tc) : 85°C
Power factor : 0,9C

Product data – type ECXd 150.604

Additional information : 35/24 mA,Irated: 150/100 mA, Urated: 20-42 Vdc, Uout: 60 Vdc,

6 W

Product data – type ECXd 250.597

Additional information : 58/46 mA, Irated: 250/200 mA, Urated: 20-42 Vdc, Uout: 60 Vdc,

10 W;

Product data – type ECXd 350.605

Additional information : 80/70 mA, Irated: 350/300 mA, Urated: 20- 42 Vdc, Uout: 60

Vdc, 15 W;

Product data - type ECXd 700.598

Additional information : 150/110 mA, Irated: 700/500 mA, Urated: 20- 42 Vdc, Uout: 60

Vdc, 30 W;

TESTS

Test requirements

EN 61347-2-13:2014 EN 61347-2-13:2014/A1:2017 EN 61347-1:2015

EN 61347-1:2015/A1:2021

EN IEC 62384:2020

Test result

The test results are laid down in DEKRA test file 438413200, 490561200.

Additional information

This certificate replaces certificate No. 35-123059 which we hereby declare invalid.

The list of components is laid down in test report 4384132.50, 4905612.50.



ANNEX TO ENEC CERTIFICATE 35-129884

page 2 of 3

Conclusion

The examination proved that all requirements were met.

Factory location



ANNEX TO ENEC CERTIFICATE 35-129884

page 3 of 3

 $Trade\ name (s):\ VS\ LIGHTING\ SOLUTIONS\ stands\ for$

