

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

## Product

Electronic controlgear for LED modules (Constant Current LED Power Supply)


## Name and address of the applicant

Vossloh-Schwabe Deutschland GmbH  
Stuttgarter Str. 61/1, 73614 Schorndorf, Germany

## Name and address of the manufacturer

Vossloh-Schwabe Deutschland GmbH  
Stuttgarter Str. 61/1, 73614 Schorndorf, Germany

## Name and address of the factory

*When more than one factory*☐ Additional information on page 2

## Ratings and principal characteristics

## Product data

Ratings:  $U_{in}$ : 220 - 240 Vac; 50/60 Hz (220 – 240 Vdc / 176 – 276 Vdc for emergency use; 0 Hz);  $I_{in}$ : 0,565 A max;  
Rated: 200 - 700 mA;  $U_{rated}$ : 40-240 Vdc;  $U_{out}$ : 275 Vdc max;  
Prated: 91 W max; Constant current;  $t_a$ : 50 °C;  $t_c$ : 75 / 80 °C; Built-in;  
Auto-wound.

## Trademark / Brand (if any)



VS LIGHTING SOLUTIONS

## Customer's Testing Facility (CTF) Stage used

## Model / Type Ref.

ECXe 350.738, ECEX 350.739, ECEX 350.740, ECEX 500.741,  
ECEX 500.742 and ECEX 700.743

## Additional information

☐ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014,  
IEC 61347-2-13:2014/AMD1:2016 and IEC 62384:2020

## National differences:

AU, EU Group Differences, NZ

As shown in the Test Report Ref. No. which forms part of this Certificate

6217891.50 and 6217891.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051  
6825 MJ Arnhem  
Netherlands

Date: 2025-04-27

Signature: May Liu