



Ref. Certif. No

NO135019

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

## Product

LED Power Supply

## Name and address of the applicant

Vossloh-Schwabe Deutschland GmbH  
Stuttgarter Straße 61/1  
73614 Schorndorf  
Germany

## Name and address of the manufacturer

Vossloh-Schwabe Deutschland GmbH  
Stuttgarter Straße 61/1  
73614 Schorndorf  
Germany

## Name and address of the factory

Note: When more than one factory, please report on page 2

☐ Additional Information on Page 2

## Ratings and Principal characteristics

PRI: max. 0.26 A, 220-240 V~, 0/50/60 Hz  
Centralized emergency power supply: 220-240 Vd.c.  
SEC: max. 42 W, max. 1.05 A, 2.5-49 Vd.c. (under load), max. 59 Vd.c. (no-load). EOFI: 100%  
VS LIGHTING SOLUTIONS

## Trademark /Brand (If any)

## Customer's Testing Facility (CTF) Stage used

## Model/Type Ref

ECXd 1050.758

## Additional information (If necessary may also be reported on Page 2)

☒ Additional Information on Page 2

## A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017  
IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016

## As shown in the Test Report Ref. No. which forms part of this Certificate

REP095863

This CB Test Certificate is issued by the National Certification Body

Philip Pedersen vei 11,  
NO-1366 Lysaker, Norway  
Date: 30-05-2025Signature: Yasaman Vadoudi  
Certification department



Ref. Certif. No

**NO135019**

### Additional Information (if necessary)

Independent type with terminal cover incl. strain relief, Class II; Built-in type without terminal cover. SELV, constant current output, thermal protected 110 °C, ta: 40°C, tc: 85 °C.



Philip Pedersen vei 11,  
NO-1366 Lysaker, Norway  
**Date:** 30-05-2025

**Signature:** Yasaman Vadoudi  
Certification department