

CERTIFICATE

Issued to:

Applicant:

Vossloh-Schwabe Deutschland GmbH
Stuttgarter Straße 61/1 73614 Schorndorf Germany

Licensee:

Vossloh-Schwabe Deutschland GmbH
Stuttgarter Straße 61/1 73614 Schorndorf Germany

Product : LED Power Supply
Trade name(s) : VS LIGHTING SOLUTIONS
Type(s)/model(s) : ECXe 1050.825 and ECXe 400.828

The product and any acceptable variation thereof as specified in the Annex to this certificate and the documents referred to therein.

DEKRA hereby declares that the above-mentioned product has been certified based on:

- a type test according to EN IEC 61347-1:2024, EN IEC 61347-2-13:2024 and EN IEC 62384:2020
- an inspection of the factory location according to CENELEC Operational Document CIG 421
- a DEKRA certification agreement with the number 6061104

DEKRA hereby grants the right to use the ENEC certification mark.


The ENEC certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the ENEC certification agreement.

This licence has been issued under the presumption and conditional on the fact that the licensee holds all necessary legal rights with regard to the product presented for testing and certification.

This certificate is issued on 11 May 2026 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 35-175601

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



Kreny Lin
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: LED Power Supply
Trade name(s)	: VS LIGHTING SOLUTIONS
Type(s)/model(s)	: ECXe 1050.825 and ECXe 400.828
Rated voltage	: 220-240 V
Ambient temperature (ta)	: 35°C
Rated frequency	: 50/60 Hz
Additional information	: SELV, Built-in, constant current output, 110 °C thermal protection.

TESTS**Test requirements**

EN IEC 61347-1:2024

EN IEC 61347-2-13:2024

EN IEC 62384:2020

Test result

The test results are documented in DEKRA test file 4951377.50, 4951377.51.

Additional information

The list of components is laid down in test report 4951377.50,.

Conclusion

The examination has confirmed that all requirements were met.

Factory location

Trade name : VS LIGHTING SOLUTIONS stands for

